

## City of Austin | Austin Water

P.O. Box 1088 Austin, TX 78767 AustinWater.org

**DATE:** September 1, 2020

PROJECT: 2021 Waterline On-Call Services IDIQ

**CIP ID:** 2231.390 **IFB NO.:** CLMC813

**SUBJECT:** Letter of Clarification No. 1

The following are answers to Bidders' questions received on the above project. These answers do not modify the Bid Documents. Any modifications to the Bid Documents will be through an Addendum.

Q-1: In bid items SP510-PR3-, you refer to "CSC", is this in reference to C301

prestressed pipe or to C303 bar-wrapped pipe?

A-1: Pay Item SP510-PR3-\_ references "CSC or Welded Steel Pipe". Austin Water has no

material standards for C303 bar-wrapped pipe larger than 24" diameter, therefore, if bidding to use CSC, the bid price will be for C301 pre-stressed pipe since bid prices will include sizes larger than 24" diameter. Otherwise, the bid price will be for welded steel pipe. Note that, per SP510.13, Paragraph (31)(c), pipe replacements will typically

require a steel closure piece with a 20" flanged outlet.